

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER WELL REPORT

RECEIVED

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date of well completion.

DEC 1 1978 STATE OF OREGON
(Please type or print)
WATER RESOURCES DEPARTMENT
SALEM, OREGON

State Well No. 26s/30E-5bc

State Permit No. _____

1325
ARM

(1) OWNER:

Name Jan Sills
Address 162 LANCASTER SE.
SALEM, ORE. 97301

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 60 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: 28 gal./min. with 10 ft. drawdown after 1 hrs.
" " " " " "
" " " " " "
Bailer test 28 gal./min. with 10 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m.
Temperature of water 58° Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT GROUT
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 8 1/2 sacks
How was cement grout placed? POURED SLURRY

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County HARNEY Driller's well number _____
SW 1/4 NW 1/4 Section 5 T. 26S R. 30E W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 201 ft.
Static level 178' 4" ft. below land surface. Date 11-28-78
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 250 ft. Depth of completed well 250 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOPSOIL	0	3	—
SAND CONGLOMERATE ^{MED} BROWN	3	110	—
BROWN CLAY WITH FINE GRAVEL	110	130	—
BROWN CLAY WITH MED GRAVEL / FINE SAND ^{BLACK}	130	190	—
DIATOMACEOUS EARTH	190	201	178
BLACK CLAY - FINE	201	202	178
DIATOMACEOUS EARTH	202	208	178
CINDERS - BLACK	208	215	178
YELLOW CLAY-MED WITH BLACK CINDER	215	240	178
BASALT	240	250	178

Work started OCT 28 19 78 Completed NOV 28 19 78
Date well drilling machine moved off of well NOV 28 19 78

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John V. Oetter Date Nov 28, 19 78
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1331

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name ROSSBERG & SON IRRIGATION
(Person, firm or corporation) (Type or print)

Address Crane, Oregon Day

[Signed] John W. Rossberg
(Water Well Contractor)

Contractor's License No. 272 Date Nov 28, 19 78