

Form No.
GWS-25

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

LIC

WELL PERMIT NUMBER 248281 - -
DIV. 2 WD 15 DES. BASIN MD

APPLICANT

Lot: 10 Block: Filing: Subdiv: POPES SNOWSLIDE VALLEY RANCH

JAMES & HEATHER FELT
319 N WEBER ST
COLORADO SPRINGS, CO 80903-

APPROVED WELL LOCATION

PUEBLO COUNTY
SE 1/4 NE 1/4 Section 7
Township 24 S Range 68 W Sixth P.M.

DISTANCES FROM SECTION LINES

2590 Ft. from North Section Line
260 Ft. from East Section Line

UTM COORDINATES

Northing: Easting:

(719) 471-1212

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT


CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a tract of land of 35.50 acres described Tract 10 Pope's Snowslide Valley Ranch and being that portion of the SE 1/4 of the NE 1/4, and the NE 1/4 of the SE 1/4, Sec. 7 and the SW 1/4 of the NW 1/4, and the NW 1/4 of the SW 1/4, Sec. 8, Twp. 24 S, Rng. 68 W, Sixth P.M., Pueblo County, more particularly described on the attached exhibit A.
- 4) The use of ground water from this well is limited to fire protection, ordinary household purposes inside not more than three (3) single family dwellings, the irrigation of not more than one (1) acre of home gardens and lawns, and the watering of domestic animals.
- 5) The maximum pumping rate of this well shall not exceed 15 GPM.
- 6) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 7) This well shall be constructed not more than 200 feet from the location specified on this permit.

March 7, 2003



APPROVED
MPS


State Engineer


By

Receipt No. 0506641

DATE ISSUED 03-07-2003

EXPIRATION DATE 03-07-2005