

STATE OF COLORADO, OFFICE OF THE STATE ENGINEER

RECEIVED
NOV 02 2012
WATER RESOURCES
STATE ENGINEER
COLO

1. WELL PERMIT NUMBER 287915
2. OWNER NAME(S): BAIR, DOUG
Mailing Address: 626 PARADISE LN
City, St. Zip: COLORADO SPRINGS, CO 80904
Phone :

3. WELL LOCATION AS DRILLED : 1/4 SE 1/4, Sec.: 10 Twp.: 21S Range: 71W
DISTANCES FROM SEC.LINES
ft. from (south or north) Sec. line, and ft. from (east or west) Sec. Line.
SUBDIVISION: SILVER CLIFFE HEIGHTS LOT : 47 BLOCK : FILING (UNIT) : 15
STREET ADDRESS AT WELL LOCATION: EASTING: 473308.9 NORTHING: 4231765.0

4. PUMP DATA Type: SUBMERSIBLE Installation Completed 8/7/2012
Pump Manufacturer FPS Pump Model No.: 7F4P5X18-S2
Design GPM 5.0 at RPM: 3450 ,HP: 3/4 ,Volts: 230 , Full Load Amps: 8
Pump Intake Depth 260 Feet, Drop/Column Pipe Size 1" INCHES, KIND SCH 80, PVC

ADDITIONAL INFORMATION FOR PUMPS GREATER THAN 50 GPM

TURBINE DRIVER TYPE Electric Engine Other: _____
Design Head _____ feet, Number of Stages _____ , Shaft size _____ Inches.

5. OTHER EQUIPMENT
Airline Installed Yes No, Orifice Depth ft. _____ , Monitor Tube Installed Yes No, Depth ft. _____
Flow Meter Mfg. _____ Meter Serial No. _____
Meter Readout Gallons, Thousand Gallons, Acre feet, Beginning Reading _____

6. TEST DATA		Check box if Test data is submitted on Supplemental Form.			
		Date	8/7/2012		
Total Well Depth	260	Time	AM		
Static Level	105	Rate (GPM)	2		
Date Measured	8/7/2012	Pumping Lvl.	260		

7. DISINFECTION : Type CHLORINE BLEACH Amt. Used 3 CUP HTH

8. Water Quality analysis available. Yes No

9. Remarks _____

10. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge, (Pursuant to Section 24-4-104 m(13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.)
CONTRACTOR: RICK'S PUMP SERVICE Phone: 719-275-7384 Lic. No. 1331
Mailing Address P.O. BOX 1563 CANON CITY, CO 81215

Name/Title (please type or print) Rick Greenstreet/Owner
Signature 
Date 10-15-12