

EXPIRATION DATE:
4/23/03

PERMIT FEE:
\$110.00 Pd. Rec. #352939

PERMIT NO.:
02-169

FREMONT COUNTY INDIVIDUAL SEWAGE DISPOSAL PERMIT

OWNER:	TIM & JODIE FURLONG	APPLICANT:	LEGACY BUILDERS
ADDRESS:		ADDRESS:	P.O. BOX 275
CITY, STATE:		CITY, STATE:	COTOPAXI, CO
PHONE #		PHONE #	942-4150
	ZIP:		81223

CONTRACTOR:		PHONE #		LICENSE: #	
ADDRESS OF PROPERTY:	4330 Eikhorn Road, Cotopaxi, CO 81223				
LEGAL DESCRIPTION OF PROPERTY:	Lot 63, Cody Park, Filing #4				
LOT SIZE:	35 Acres	SOURCE, TYPE OF WATER SUPPLY:	Existing Well		
TYPE OF STRUCTURE:	Site Built Home	USE OF STRUCTURE:	Residential		
MAX. POTENTIAL # OF BEDROOMS	3	BASEMENT:	NO	WASHER:	YES
		GARBAGE DISPOSAL:	NO		
ENGINEERING FIRM:	Carroll J. Moench			PROJECT #	02-04-10
TYPE OF SYSTEM:	Absorption	TANK SIZE:	1000	GALLONS	
ABSORPTION AREA:	598	SQ. FT.:		PERC RATE:	10 MIN/INCH
				LTAR:	
NOTES:	Maintain all separations, keep excavations shallow, locate leachbed in designated location.				
IS SITE WITHIN 400 FT OF SEWER MAIN?	NO	OR WITHIN A SEWER DISTRICT?	NO		
IF YES, IS A LETTER OF REFUSAL TO CONNECT ATTACHED?	N/A				
IS SITE IN A DESIGNATED FLOOD PLAIN?	NO	IF YES, ENGINEER'S REQUIREMENTS LISTED?	N/A		

ON-SITE INSPECTION INFORMATION

TANK INFORMATION:						
Size	1250	gallons;	Number of compartments:	2	Is entrance and exit sealed?	YES
Is tank level?	YES	Pipe inlet-outlet?	3034	Dist. From bldg.	18	ft.;
				Dist. From well	135	ft.
ABSORPTION BED INFORMATION:						
Type of system installed:	Absorption bed	<input type="checkbox"/>	Absorption trench	<input checked="" type="checkbox"/>		
Width	3	ft.;	Length	64	ft.;	Number trenches:
						2
Depth Gravel	—	inches	Is pipe level?	YES	If bed, has the pipe been connected?	YES
Dist. From well	100	ft.;	Dist. From bldg	100	ft.;	Is system located in the recommended area?
						YES

DEPARTMENT USE ONLY

PERMIT HAS BEEN: APPROVED DISAPPROVED

DATE: 9-23-02

NOTES:

INSPECTOR'S SIGNATURE:  **DATE:** 9-23-02