

Form No.
GWS-25

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

1280

WELL PERMIT NUMBER 236697
DIV. 2 WD 12 DES. BASIN MD

APPLICANT

Lot: 63 Block: Filing: 4 Subdiv: CODY PARK

TIM & JODIE FURLONG
202 ROCKLEDGE CT
MANITOU SPRINGS, CO 80829-2325

APPROVED WELL LOCATION
FREMONT COUNTY
SE 1/4 NE 1/4 Section 21
Township 20 S Range 72 W Sixth P.M.

DISTANCES FROM SECTION LINES
2400 Ft. from North Section Line
1300 Ft. from East Section Line

UTM COORDINATES
Northing: Easting:

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT
CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a tract of land of 35 acres described as lot 63, filing 4, Cody Park division of land, Fremont County.
- 4) The use of ground water from this well is limited to fire protection, ordinary household purposes inside not more than three (3) single family dwellings, the irrigation of not more than one (1) acre of home gardens and lawns, and the watering of domestic animals.
- 5) The maximum pumping rate of this well shall not exceed 15 GPM.
- 6) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 7) This well shall be constructed not more than 200 feet from the location specified on this permit.

MPS
09/27/2001

APPROVED
MPS

Hal D. Simpson
State Engineer

Michael P. Schuch
By

Receipt No. 0482595

DATE ISSUED **OCT 04 2001**

EXPIRATION DATE **OCT 04 2003**