

From: dora_no-reply_ep_permits@state.co.us
Sent: Wednesday, March 13, 2024 12:13 AM
To: mcdanielcharles810@gmail.com
Subject: Inspection Report for Permit: 996340

166-41-609



COLORADO STATE ELECTRICAL BOARD
1560 Broadway, Suite 1350
Denver, Colorado 80202

Automatic email - Do not reply to this email.

Inspection Report

Permit #: 996340 **Date Inspected:** 12-MAR-24
Permit Holder: CHARLES MCDANIEL
8584 COUNTY ROAD 328 WESTCLIFFE 812528707
Phone: (719) 783-4050 **Fax:**
Email: mcdanielcharles810@gmail.com
Site: 1441 cr.310 Westcliffe **County:** Custer
Owner: Ben Troyer **Phone:** (719) 783-4050
Ben Troyer
Status: ACCEPTED
Inspection Type: Rough In **Trim Permit:** N
Constuction Type: NEW **Building Type:** RESIDENTIAL
Inspector: Paul Laird 303-894-2307
Corrections:
Comments: Rough in -Ok to cover. No exterior disconnect or grounding electrode system installed.
Unable to view crawl space due to no ladder. Please ensure crawl space has light/switch for final.



100.41-609

Dorothy Carsten <pzdirector@custercounty-co.gov>

Fwd: Inspection Report for Permit: 994763

1 message

Ben Lee Troyer <oakridgehome2022@gmail.com>
To: "pzdirector@custercounty-co.gov" <pzdirector@custercounty-co.gov>

Wed, Jul 24, 2024 at 2:44 PM

----- Forwarded message -----
From: **Jason Mulso** <jasonmulso@yahoo.com>
Date: Wed, Jul 17, 2024 at 7:59 PM
Subject: Fwd: Inspection Report for Permit: 994763
To: Ben Lee Troyer <oakridgehome2022@gmail.com>

Sent from my iPhone

Begin forwarded message:

From: dora_no-reply_ep_permits@state.co.us
Date: July 17, 2024 at 12:14:25 AM MDT
To: jasonmulso@yahoo.com
Subject: **Inspection Report for Permit: 994763**

COLORADO STATE PLUMBING BOARD
1560 Broadway, Suite 1350
Denver, Colorado 80202

Automatic email - Do not reply to this email.

Inspection Report

Permit #: 994763

Date Inspected: 16-JUL-24

Permit Holder:

Jason Mulso
1734 Willow St
Brookside 812125146
Phone: (719) 371-2540 **Fax:**
Email: jasonmulso@yahoo.com
Site: 1441 Cty. Rd. 310 1441 Cty. Rd. 310 Westcliffe **County:** Custer
Owner: Ben Troyer
1441 Cty. Rd. 310 **Phone:** (719) 371-2540

Status:

ACCEPTED
Inspection Type: Final **Trim Permit:** N
Construction Type: NEW **Building Type:** RESIDENTIAL

Inspector: Samuel Toman 303-869-3443

Corrections:

Comments: 1) HA's at DW, IM, WB 2) Hi Loop for DW installed 3) AAV's at KS, Hall Lav. Mud room sink 4) Hall shower 109 degf 5) Elec. WH in pan 6) T&P to pan, pan to FD 7) Master shower 110 degf 8) Ext C/O installed 2 way

Dear valued customer,

In our continuing effort to provide the very best customer service, a customer satisfaction survey is being made available to you. If you have already responded to our request by taking this brief survey, thank you for taking the time to do so. If you have not yet responded, we would appreciate your feedback by taking this anonymous survey.

Thank you in advance for your input, which we will use in our continuing efforts to make every consumer's experience a positive one.

The survey may be accessed by clicking this link: Survey

