



# CUSTER COUNTY PERMIT FOR INSTALLATION OF ON-SITE WASTEWATER TREATMENT SYSTEM

101-18-302

S16102601

Issue Date: 10/26/2016

Joyce Gregor  
936 County Road 137  
Westcliffe, CO 81252  
(719) 783-9129

Septic Contractor: Ed Lyons Applicant: Owner

Permit Type: Repair System Type: Standard

Property Address: 936 County Road 137

Legal: Ley, Lot 26

Lot size: 3.3 acres Number of people: 4 Number of bedrooms: 2 Tank Size: 1000

This septic will serve a Dwelling Water: Private Well

Comments:

I hereby certify that I have installed this system as designed:

  
\_\_\_\_\_  
Licensed Contractor / Homeowner


10-28-16  
\_\_\_\_\_  
Date

Inspected on: 10/27/16

By: JSH

Amount use tax paid: none

Date: \_\_\_\_\_

  
\_\_\_\_\_  
Zoning Office / Inspector

Final approval date: 11/1/16

# Septic Inspection

Date: 10-27-16

Property Owner(s): **Joyce Gregor**

Inspected By: JSH

Property Address: **936 County Road 137**

Legal: **Ley, Lot 26**

Septic Contractor: **Ed Lyons**

Schedule #: **101-18-302**

Permit Number: **S16102601**

Distance of Pipe from House to Tank: Existing

Distance DBL Cleanouts: \_\_\_\_\_

Number of cleanouts needed (50 feet): \_\_\_\_\_

Check slope (1/2 inch per 2 feet for last 10 feet before tank): \_\_\_\_\_

Type of pipe (schedule number): \_\_\_\_\_

Building Sewer extended to foundation: \_\_\_\_\_

Tank size: Existing Is tank level?: \_\_\_\_\_

Check: Inlet \_\_\_\_\_ Outlet \_\_\_\_\_

Check for cracks in tank: \_\_\_\_\_ Date on tank: \_\_\_\_\_

Distance of pipe from tank to leach field: 23' Check for slope: ok

Check for level distribution field: ok Type of pipe (schedule number) Sch 40

Type of leach field: Rock & Pipe Number, if chambers: NA

Check for screws on chamber connections: (2) 400' Run 800sq ft

Configuration: Trench or Bed (Max 12' wide, 4' deep) Check for level: \_\_\_\_\_

Depth: 2 Check distance between trenches (4 feet minimum): ok

Distance from well to tank: 100' Distance from well to leach field: 100'  
(50 feet minimum) (100 feet minimum)

Distance from leach field to any irrigation ditch or creek: \_\_\_\_\_

(Minimums: Cistern - 25'; property line - 10'; water course - 50'; dry gulch - 25')

Additional comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



# CUSTER COUNTY PERMIT FOR INSTALLATION OF ON-SITE WASTEWATER TREATMENT SYSTEM

101-18-302

S21120321

Issue Date: 12/3/2021

**Tammy Williams**  
936 CR 137  
Westcliffe, CO 81252  
(719) 600-7684

Septic Contractor: **Ed Lyons** Soil done by: **NONE N/A** Applicant: **Owner**

Permit Type: **Modification** System Type: **Standard**

Property Address: **936 CO RD 137**

Legal: **LOT 26 LEY SUB**

Lot size: **3.3** Number of people: **10** Number of bedrooms: **5** Tank Size: **1500**

This septic will serve a **Dwelling** Water: **Private Well**

Conditions: Depth to bedrock: **>96"** Depth to water: **>96"** Slope:

Soil Type: **2** Treatment Level: **1** Effluent Application Method: **Gravity**

	Rock or Tire Chips Sq. Ft.	Mfd Media other than Chambers Sq. Ft.	Chambers Sq. Ft.	Number of Chambers
Trench	1250	1125	875	73
Bed	1500	1350	1050	88

Comments:

**I hereby certify that I have installed this system as designed:**

  
\_\_\_\_\_  
Licensed Contractor / Homeowner

3/21/2022  
\_\_\_\_\_  
Date

Inspected on: 12/21/2022

By: JSH

Amount use tax paid: \_\_\_\_\_

Date: \_\_\_\_\_

  
\_\_\_\_\_  
Zoning Office / Inspector

Final approval date: 3/21/2022

# Septic Inspection

Property Owner(s): **Tammy Williams**

Date: 12-21-2021

Property Address: **936 CO RD 137**

Inspected By: JSH

Legal: **LOT 26 LEY SUB**

Septic Contractor: **Ed Lyons**

Schedule #: **101-18-302**

Permit Number: **S21120321**

Distance of Pipe from House to Tank: 20' New Tank  
Distance DBL Cleanouts: na  
Number of cleanouts needed (50 feet): na  
Check slope (1/2 inch per 2 feet for last 10 feet before tank): OK  
Type of pipe (schedule number): Sch 40  
Building Sewer extended to foundation: yes

Tank size: 1000 Is tank level?: OK  
Check: Inlet OK Outlet OK  
Check for cracks in tank: \_\_\_\_\_ Date on tank: \_\_\_\_\_

Distance of pipe from tank to leach field: 49' Check for slope: OK  
Check for level distribution field: OK Type of pipe (schedule number) Sch 40

Type of leach field: Pipe & Rock Number, if chambers: 12 x 6' = 800 Sq Ft  
Check for screws on chamber connections: OK  
Configuration: Trench or Bed (Max 12' wide, 4' deep) Check for level: OK  
Depth: 2-2 1/2 Check distance between trenches (4 feet minimum): na

Distance from well to tank: 100' Distance from well to leach field: 100'  
(50 feet minimum) (100 feet minimum)  
Distance from leach field to any irrigation ditch or creek: \_\_\_\_\_  
(Minimums: Cistern - 25'; property line - 10'; water course - 50'; dry gulch - 25')

Additional comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_