

FORM NO.
GWS-31
11/90

WELL CONSTRUCTION AND TEST REPORT-
STATE OF COLORADO, OFFICE OF THE STATE ENGINEER

For Office Use only

1. WELL PERMIT NUMBER 249449

DEC 19 2003

2. OWNER NAME(S) ROBERT A. GERREN
Mailing Address 206 WOLFE AVE
City, St. Zip COLORADO SPRING CO. 80906
Phone (719) 633-4326

WATER RESOURCES
STATE ENGINEER
COLORADO
0508362

3. WELL LOCATION AS DRILLED: SW 1/4 NE 1/4, Sec. 2 Twp. 27 S, Range 71 W 6 TH PM
DISTANCES FROM SEC. LINES:
1950 ft. from NORTH Sec. line, and 2350 ft. from EAST Sec. line. OR
(north or south) (east or west)
SUBDIVISION: _____ LOT _____ BLOCK _____ FILING(UNIT) _____
STREET ADDRESS AT WELL LOCATION: _____

4. GROUND SURFACE ELEVATION 6260 ft. DRILLING METHOD ROTARY AIR
DATE COMPLETED 10/21/03 TOTAL DEPTH 225 ft. DEPTH COMPLETED 226 ft.

5. GEOLOGIC LOG:
Depth Description of Material (Type, Size, Color, Water Location)
0-3 SOIL
3-10 ROCK CLAY
10-30 CLAY SAND
30-50 GRAVEL
50-60 CLAY
60-225 SAND ROCK CLAY Redd

WATER 180

REMARKS: _____

6. HOLE DIAM. (In.)	From (ft)	To (ft)
<u>9 3/4</u>	<u>0</u>	<u>60</u>
<u>7 7/8</u>	<u>60</u>	<u>225</u>

7. PLAIN CASING				
OD (In)	Kind	Wall Size	From (ft)	To (ft)
<u>8 1/2</u>	<u>STEEL</u>	<u>250</u>	<u>0</u>	<u>60</u>
<u>5 1/2</u>	<u>PVC</u>	<u>1/2 INCH</u>	<u>10</u>	<u>80</u>
PERF. CASING: Screen Slot Size: <u>1/2 INCH</u>				
<u>5 1/2</u>	<u>PVC</u>	<u>1/2 INCH</u>	<u>80</u>	<u>225</u>

8. FILTER PACK:	9. PACKER PLACEMENT:
Material _____	Type _____
Size _____	Depth _____
Interval _____	

10. GROUTING RECORD:				
Material	Amount	Density	Interval	Placement
<u>CEMENT</u>	<u>10SK</u>	<u>SLURRY</u>	<u>39</u>	<u>POURD</u>

11. DISINFECTION: Type BLACH Amt. Used 4 CUP

12. WELL TEST DATA: Check box if Test Data is submitted on Supplemental Form.
TESTING METHOD _____
Static Level 4 ft. Date/Time measured 10/21/10:00, Production Rate 40 gpm.
Pumping level 220 ft. Date/Time measured 10/21/1:00, Test length (hrs.) 1 HR
Remarks _____

13. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. [Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.]

CONTRACTOR ROBERT PFAFFENHAUSER Phone (719) 744 2981 Lic. No. 9655
Mailing Address PO BOX 843 WALSBURG COLO 81089

Name/Title (Please type or print) TIMBERLINE DRILLING Signature Robert Pfaffenhauser Date 10/21/03