




Job #61664463

Septic Tank Inspection - Class A

Septic System Information <input checked="" type="checkbox"/> Septic tank with leach field / seepage pit(s):	Age of System: Year current septic system was installed. 17yrs
Last Time Tank was Pumped or Maintained ? Approximately Based on current homeowners information Never pumped	Size of Home: How many Bathrooms? 2
Is Septic System Adequate for Size of Home: <input checked="" type="checkbox"/> Yes	Tank Capacity (gallons): ` 1000
Number of Compartments: 2	Number of Access Lids: 2
Access Lid Diameter: 24in round	Depth to Access Lid(s): 6in
Access Risers Present? <input checked="" type="checkbox"/> No	If Risers are Present- How Many? -
Septic Tank Construction: Shape <input checked="" type="checkbox"/> Rectangular	Septic Tank Construction: Material <input checked="" type="checkbox"/> Concrete
Septic Tank Condition: <input checked="" type="checkbox"/> Lids Good <input checked="" type="checkbox"/> Baffle Wall Good <input checked="" type="checkbox"/> Tank Good	Inlet Tee Present <input checked="" type="checkbox"/> Yes
Outlet Tee Present: <input checked="" type="checkbox"/> Yes	Riser Lids Seal Properly:
Heavy Grease Build Up:	Overall Condition: 
Is water level normal (at level of outlet, 12 to 15 inches below tank ceiling)? <input checked="" type="checkbox"/> Yes	At Current State is effluent above the outflow tee? <input checked="" type="checkbox"/> No
Signs of surfacing effluent observed? <input checked="" type="checkbox"/> No	Any signs of past drainage problems? <input checked="" type="checkbox"/> No

System appears to be function Satisfactorily?

Yes

Does Septic Tank need pumped?

Yes

Septic Tank Location:

Picture of tanks location:



Septic Tank Condition:

Image of Tank at Time of Inspection



Summary of Maintenance Performed

Repairs or Upgrades Required

Needs pumped

Comments or Recommendations:

Needs pumped

Outcome of Inspection

Pass

Signature of Inspector:

Note:

This Inspection Report is based on the condition of the septic system at time of inspection. Roto-Rooter Plumbers does not offer any warranties, either expressed or implied, as to the findings or condition of the inspection.

2022-09-16