

GWS-32
11/90

"PUMP INSTALLATION AND TEST REPORT"
STATE OF COLORADO, OFFICE OF THE STATE ENGINEER

For office use only

1. WELL PERMIT NUMBER 228915

2. OWNER NAME(S): WOODARD, CRAIG
Mailing Address: 7655 MOUNTAIN VALLEY RD
City, St. Zip: MOUNTAIN GROVE, MO 65711
Phone : 417-349-8113

RECEIVED

MAY 18 2012

WATER RESOURCES
STATE ENGINEER
COLO.

3. WELL LOCATION AS DRILLED : SW 1/4 NE 1/4, Sec.: 26 Twp.: 20 S Range: 73 W
DISTANCES FROM SEC.LINES
1840 ft. from NORTH Sec. line, and 1535 ft. from EAST Sec. Line.
(south or north) (east or west)
SUBDIVISION: COLORADO ACRES LOT : 92 BLOCK : _____ FILING (UNIT) : _____
STREET ADDRESS AT WELLLOCATION: _____

4. PUMP DATA Type: SUBMERSIBLE Installation Completed 10/17/2011
Pump Manufacturer FPS Pump Model No.: 1F4P5X21-S2
Design GPM 5.0 at RPM: 3450 , HP: 1 HP , Volts: 230 , Full Load Amps: 9.8
Pump Intake Depth 575 Feet, Drop/Column Pipe Size 1" INCHES, KIND SCH 80, PVC

ADDITIONAL INFORMATION FOR PUMPS GREATER THAN 50 GPM

TURBINE DRIVER TYPE Electric Engine Other: _____
Design Head _____ feet, Number of Stages _____ , Shaft size _____ Inches.

5. OTHER EQUIPMENT

Airline Installed Yes No, Orifice Depth ft. _____, Monitor Tube Installed Yes No, Depth ft. _____
Flow Meier Mfg. _____ Meter Serial No. _____
Meter Readout Gallons, Thousand Gallons, Acre feet, Beginning Reading _____

6. TEST DATA

Check box if Test data is submitted on Supplemental Form.

Total Well Depth	<u>650</u>	Date	<u>10/17/2011</u>	_____	_____
Static Level	<u>100</u>	Time	<u>PM</u>	_____	_____
Date Measured	<u>10/17/2011</u>	Rate (GPM)	<u>5</u>	_____	_____
		Pumping Lvl.	<u>550</u>	_____	_____

7. DISINFECTION : Type CHLORINE BLEACH Amt. Used 3 CUP HTH


8. Water Quality analysis available. Yes No

9. Remarks _____

10. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge, (Pursuant to Section 24-4-104 m(13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.)

CONTRACTOR: RICK'S PUMP SERVICE Phone: 719-275-7384 Lic. No. 1331
Mailing Address P.O. BOX 1563 CANON CITY, CO 81215

Name/Title (please type or print)
Rick Greenstreet/Owner

Signature


Date
5-14-12

Form no. GWS - 31 11/90

WELL CONSTRUCTION AND TEST REPORT STATE OF COLORADO, OFFICE OF THE STATE ENGINEER

for office use only 0466631 RECEIVED NOV 16 2000

1. WELL PERMIT NUMBER 228915

2. OWNER NAME(S): SUPERIOR HOMES C/O SUPERIOR HOMES Mailing Address: P.O. BOX 149 City, St. Zip: CANON CITY, CO 81215 Phone: (719) 269-1890

WATER RESOURCES STATE ENGINEER

3. WELL LOCATION AS DRILLED: SW 1/4 NE 1/4, Sec.: 26 Twp.: 20 S Range: 73 W DISTANCES FROM SEC. LINES 1840 ft. from NORTH Sec. line, and 1535 ft. from EAST Sec. Line OR (south or north) (east or west) SUBDIVISION: COLORADO ACRES LOT: 92 BLOCK: FILING (UNIT): STREET ADDRESS AT WELL LOCATION:

4. GROUND SURFACE ELEVATION: ft. DRILLING METHOD AIR PERCUSSION DATE COMPLETED: 11-03-00 TOTAL DEPTH: 650 ft. DEPTH COMPLETED: 650 ft.

5. GEOLOGIC LOG: Depth Description of Material (Type, Size, Color, Water location) 0-2 BROWN TOPSOIL 2-117 LOOSE SAND & GRAVEL 117-210 TAN & RED GRANITE 210-650 GRAY GRANITE REMARKS: WATER 620'

6. HOLE DIAM. (in.) From (ft) To (ft) 8 3/4 0 119 6 119 650

7. PLAIN CASING OD (in) Kind Wall Size From (ft) To (ft) 6 5/8 STEEL .188 1+ 119 4 1/2 PVC .214 10 550 4 1/2 PVC .214 570 590 4 1/2 PVC .214 610 630 PERF. CASING Screen Slot Size 3/32" 4 1/2 PVC .214 550 570 4 1/2 PVC .214 590 610 4 1/2 PVC .214 630 650

8. FILTER PACK 9. PACKER PLACEMENT Material: Type: FORMATION Size: Depth: 39' Interval:

10. GROUTING RECORD: Material Amount Density Interval Placement CEMENT 6 SACKS 15.3 9'-39' Poured Vibrated

11. DISINFECTION, Type CHLORINE Amt. Used: 1 GALLON, WATER INJ., 18 HRS

12. WELL TEST DATA [] Check box if test data is submitted on supplemental form TESTING METHOD: AIR LIFT Static Level: 100 ft. Date/Time Measured: 11-03-00 4:00PM Production Rate 2 gpm. Pumping Level: 650 ft. Date/Time Measured: 11-03-00 5:00PM Test Length (hrs) 1 Remarks:

13. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. (pursuant to section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.

CONTRACTOR: YOUNG'S DRILLING & PUMP SVCS. INC. PHONE: (719) 275-5482 Lic. No.: 1305 Mailing Address: P.O. BOX 2123 CANON CITY, CO 81215

Name/Title (please type or print) Todd A Moore (Partner) Signature Date 11/14/00

