

FORM NO.
GWS-31
04/2005

WELL CONSTRUCTION AND TEST REPORT

STATE OF COLORADO, OFFICE OF THE STATE ENGINEER
1313 Sherman St., Room 818, Denver, CO 80203
Phone - Info (303) 866-3587 Main (303) 866-3581
Fax (303) 866-3589 http://www.water.state.co.us

For Office Use Only

RECEIVED

AUG 09 2010

WATER RESOURCES
STATE ENGINEER
COLO.

1. WELL PERMIT NUMBER: 282684

2. WELL OWNER INFORMATION

NAME OF WELL OWNER: PREMO, JAY

MAILING ADDRESS: 2900 CR 1

CITY: COTOPAXI

STATE: CO

ZIP CODE: 81223

TELEPHONE NUMBER: (719) 371-2874

3. WELL LOCATION AS DRILLED: SW1/4, SE1/4, Sec. 3, Twp. 20 N or S, Range 72 E or W

DISTANCES FROM SEC. LINES: 823 ft. from N or S section line and 1798 ft. from E or W section line.

SUBDIVISION: HALLS, LOT 2, BLOCK, FILING (UNIT)

Optional GPS Location: GPS Unit must use the following settings: Format must be UTM, Units must be meters, Datum must be NAD83, Unit must be set to true N, Zone 12 or Zone 13

Owner's Well Designation:
Easting: 463885

STREET ADDRESS AT WELL LOCATION:

Northing: 4243215

4. GROUND SURFACE ELEVATION feet

DATE COMPLETED 3-18-10

TOTAL DEPTH 200

DRILLING METHOD AIR PERCUSSION

feet DEPTH COMPLETED 200 feet

5. GEOLOGIC LOG:

Depth	Type	Grain Size	Color	Water Loc.
0-6	TOPSOIL		BROWN	
6-30	GRAVEL	3/4	MULTI	
30-140	GRANITE		PINK	
140-200	GRANITE		GREY	

6. HOLE DIAM (in.) From (ft) To (ft)

8 3/4	0	39
6 1/8	39	200

7. PLAIN CASING:

OD (in)	Kind	Wall Size (in)	From (ft)	To (ft)
6 5/8	STEEL	.188	+1	39
4 1/2	PVC	.237	20	100
4 1/2	PVC	.237	180	200
4 1/2	PVC	.237		

PERFORATED CASING: Screen Slot Size (in): .030

4 1/2	PVC	.237	100	180
4 1/2	PVC	.237		
4 1/2	PVC	.237		
4 1/2	PVC	.237		

8. FILTER PACK:

Material
Size
Interval

9. PACKER PLACEMENT:

Type
Depth

10. GROUTING RECORD

Material	Amount	Density	Interval	Placement
CEMENT	5 BAGS	15.3	3-40	POURED

Remarks:

11. DISINFECTION: Type CHOLORINE BLEACH

Amt. Used 1/2 GAL. WTR INJECTION OVERNIGHT

12. WELL TEST DATA: Check box if Test Data is submitted on Form Number GWS 39 Supplemental Well Test.

TESTING METHOD AIRLIFT

Static Level 75 ft. Date/Time measured: 3-18-2010 12:00 PM, Production Rate 1 gpm.

Pumping Level 200 ft. Date/Time measured 3-18-2010 2:00 PM, Test Length (hrs) 2.

Remarks:

13. I have read the statements made herein and know the contents thereof, and they are true to my knowledge. This document is signed and certified in accordance with Rule 17.4 of the Water Well Construction Rules, 2 CCR 402-2. [The filing of a document that contains false statements is a violation of section 37-91-108(1)(e), C.R.S., and is punishable by fines up to \$5000 and/or revocation of the contracting license.]

Company Name:
YOUNG'S DRILLING & PUMP SERVICES

Phone:
(719)275-5482

License Number:
592

Mailing Address: P.O. BOX 2123 CANON CITY, CO. 81215

Signature: Robert Young

Print Name and Title
ROBERT YOUNG - OWNER

Date
8-2-10