

County: Worth
Permit Number: OSC15901688
Property Address: 115 WYNN DR SYLVESTER, GA 31791
Property Owner: KAREN CONROY

Remarks: Grades good. Soils good. Installed in suitable area. Contractor dug up concrete on right side of house but it did not appear to be an old tank. Plenty of cover onsite per contractor. Tank is greater than 140' from well. 6" of fall from tank to drain field. Do not park or drive on system.

