

Tara Cromwell  
MOORE COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH SECTION

383 Ellis Ln

10001176

SUBSURFACE SEWAGE DISPOSAL SYSTEM  
PERMANENT RECORD

2 Bedroom Septic

Installer Larry Sharpe Phone 499 6160

Address Sanford

Tank Capacity 1000 Tank I.D. # 6-2 C\$1000 STB 939

Nitrification Line Dimensions 2 @ 50' X 3'

Distribution Box yes Gravel Depth 12"

Depth to: Top of Tank 3" Trench Bottom (Average) 24"

Pump      Size      Brand Name      Pump Tank Capacity     

Diagram of Actual Installation (Depict Property Boundaries, Driveways, Trees, Water Lines, Water Supplies, Etc.)

to layout

Comments \_\_\_\_\_

Approved by: Charles D. Riggs Date: 7/29/93



# MOORE COUNTY HEALTH DEPARTMENT ENVIRONMENTAL HEALTH SECTION


P. O. BOX 279, CARTHAGE, N. C. 28327  
PHONE: 947-2858

## IMPROVEMENT PERMIT

Owner Tara Jean Cromwell Property Identification # \_\_\_\_\_  
Address Rt 1 Box 370-E, Aberdeen 28315 Phone No. 281-5716  
Exact Directions to Property Hwy 211 - Turn at Arbor Nursery - TR 2784'  
Lot Area 5.45 ACRES Maximum Long-Term Acceptance Rate 0.8  
(From Site Evaluation)  
Daily Design Sewage Flow Rate (From Application) 240  
Septic Tank Capacity 1000 Pump NO  
Distribution Box yes Pump Tank Capacity \_\_\_\_\_  
Depth of Gravel 12" Maximum Trench Depth 18"-30"  
Dimensions of Nitrification Lines 2 @ 50' x 3'  
Type of Water Supplies well If Well, What Type to be installed  
Distance to Water Supplies 5100' Lakes, Streams, Etc. \_\_\_\_\_  
Easement Obtained (If Necessary) \_\_\_\_\_ Repair Area Required yes

NOTE: Should discrepancies, ambiguities or omissions be noted in the drawings or specifications; or if there is doubt as to their meaning, this office should be contacted at once for an interpretation or clarification.

Diagram of Proposed Installation



Comments/Conditions

Permit Issued by: Charles D. Rife Date: 7/19/93  
Approved by: [Signature] Date: 7/29/93

This Permit Expires 60 Months from Date of Issuance and is Subject to Revocation if Site Plans or the intended use of the Property Changes.  
White Copy (Owner's Copy) Pink Copy (Electrical Inspector) Hard Copy (Office)