



**PERMIT TO CONSTRUCT
Onsite Wastewater System**

File Nbr: **2021010015**
County: **Greenville**

Name: WILLIAM TAYLOR	Address: 101 E WASHINGTON ST STE 300 GREENVILLE, SC 29601	Program Code: 360
Type Facility: HOUSE	Site: TERRY SHOP RD	System Code: 100
Subdivision: CEDAR FALLS PROPERTIES	FOUNTAIN INN, SC	TM No.: 0578.03-01-001.13
Block: 4BR Lot: 11		Water Supply: PUBLIC

PERMIT TO CONSTRUCT SYSTEM SPECIFICATIONS

Daily Flow (gpd): 480	Tank Sizes (gal): Septic Tank: 1000	Pump Chamber:	Grease Trap:
LTAR: .40	Trenches: Length (ft): 400 Width (in): 36	Max. Depth (in): 36	Agg. Depth (in): 14
Min Pump Capacity:	gpm at	ft. of head	Alternative Product:

SPECIAL INSTRUCTIONS/CONDITIONS

THIS PERMIT IS SITE SPECIFIC. ANY CHANGES TO THE SYSTEM MUST BE APPROVED BY DHEC. ALTERNATIVE TRENCH PRODUCTS APPROVED UNDER STATE RULES AND REGULATIONS MAY BE SUBSTITUTED. ANY UNAPPROVED CHANGES WILL VOID THIS PERMIT.

Installers must contact the local Environmental Affairs office by 10:00 AM on the day prior to installation in order to schedule a time for the final inspection.

If a Department representative does not arrive within 30 minutes of the scheduled time, the installer may conduct the final inspection.

When a contractor self-inspection occurs, the installer must complete the DHEC form 3978, Approval to Operate Contractor Self-Inspection.

The installer must submit DHEC form 3978 within 2 business days of the completion of the installation.

MINIMUM OFFSET TO ANY WELL 75'.

PERMIT TO CONSTRUCT SYSTEM DIAGRAM

(NTS)

See attached...

Issued/Revised By: _____

Emily Brown

Date: _____

1/28/21



APPLICATION SUPPLEMENTAL FORM

Onsite Wastewater System

File Nbr: **2021010015**

County: **Greenville**

Name: WILLIAM TAYLOR

Address:

101 E WASHINGTON ST STE 300
GREENVILLE, SC 29601

Program Code: 360

Type Facility: HOUSE

System Code:

Subdivision CEDAR FALLS PROPERTIES

Site: TERRY SHOP RD
FOUNTAIN INN, SC

TM No.: 0578.03-01-001.13


Block: 4BR

Lot: 11

Water Supply: PUBLIC

ACTUAL INSTALLATION

(NTS)



Emily Broom 1/28/21